

Quality Control



CONCRETE SUBSTRATE READINESS CHECKSHEET

Project Name: _____

Subcontractor: _____

Area ready: _____

Fax Number: _____



Concrete cured for a minimum 28 days and thoroughly dry.

Any curing compounds removed.

Surface smooth and clean with adequate falls to outlets.

Cavities and cracks filled with Gripset C-Plug mortar and flushed off.

Concrete surface firm with any soft concrete or latescence removed.

Ponding areas removed (screed out with Gripset C-Bed).

Roof drains and overflow recesses formed to fit.

Mortar fillets to all up stands and smooth (non tiled applications only - 5mm radius to all external edges).

If terminating into a chase, pre-form the chase and ensure that it is straight and 20mm deep.

Plinths formed for any exterior fixtures or similar.

Substrate clean, firm and suitable condition for laying.

WHEN THE SUBSTRATE IS READY COMPLETE THIS FORM AND FAX TO THE WATERPROOFING SUBCONTRACTOR

Notes:

