

QUALITY CONTROL



CONCRETE SUBSTRATE READINESS CHECKSHEET

Project Name:

Subcontractor:

Area ready:

Fax Number:

Concrete cured for a minimum 28 days and thoroughly dry.

Any curing compounds removed.

Surface smooth and clean with suitable falls.

Cavities and cracks filled with repair mortar and flushed off.

Concrete surface firm with any soft concrete or latescence removed.

Ponding areas removed.

Roof drains and overflow recesses formed to fit

5mm radius to all external edges.

If terminating into a chase, pre-form the chase and ensure that it is straight and 20mm deep.

Plinths formed for any exterior ventilation, fixtures or similar.

Substrate clean, firm and suitable condition for laying.

WHEN THE SUBSTRATE IS READY, COMPLETE THIS FORM AND FAX TO THE WATERPROOFING SUBCONTRACTOR.

NOTES:
